



NOTES:

1. STRUCTURE SHALL CONFORM WITH FLA. BUILDING CODE AND F.D.O.T. DESIGN STANDARDS. PROVIDE FOR A MINIMUM H-20 LOADING.
2. CAST-IN-PLACE STRUCTURES SHALL BE DESIGNED BY FLORIDA LICENSED ENGINEER.
3. PRECAST STRUCTURES SHALL CONFORM TO ASTM C478
4. LIDS SHALL BE LABELED "SAMPLE STATION".
5. INSTALLATION SHALL BE IN ACCORDANCE WITH STANDARD PLUMBING CODES.
6. INLET AND OUTLET PIPING REQUIRE A TWO-WAY CLEANOUT TEE.
7. SAMPLE STATION SHALL BE PLACED DOWNSTREAM OF ALL PRETREATMENT STRUCTURES.

SAMPLE STATION

TWA-13
2009