



SEE SPECIFICATIONS FOR ADDITIONAL INFORMATION AND REQUIREMENTS.

NOTES:

1. BEDDING SHALL BE No. 57 CRUSHED STONE, IF EARTH BEDDING IS WET.
2. PRIMARY AND SECONDARY ZONES SHALL BE INDIVIDUALLY COMPACTED LAYERS OF CLEAN FILL.
3. COMPACTION OF BACKFILL BENEATH STRUCTURES, PAVING AND PARKWAYS, SHALL BE 98% OF AASHTO T-180; ALL OTHER COMPACTION SHALL BE 95%, EXCEPT AS OTHERWISE REQUIRED BY PERMITTING AUTHORITY.
4. INSTALL CONTINUOUS 14 GAUGE INSULATED COPPER WIRE FOR ALL PIPE, EXCEPT GRAVITY SEWERS. TERMINATE THESE LOCATOR WIRES AT TOP OF EACH VALVE PAD WITH 12" OF EXTRA WIRE. CONNECT SPLICED WIRES WITH WIRE NUTS AND SEAL IN WATER-TIGHT SILICONE FILLED JACKET.
5. PLACE APPROVED METALLIC PRINTED WARNING TAPE 12"-18" ABOVE PIPE.
6. SIDE SLOPE AND BENCH PER OSHA REQUIREMENTS.

TYPICAL PIPE TRENCH SECTION