

# Construction Review Checklist of Commonly Missing Items

- Water/Storm and Sanitary/Storm crossings – with separations shown
- Temporary Jumper Connection(s) at Point of Connection
- Project Summary including number of single family, multi-family units, bedrooms per unit, building types etc. and square footage of commercial space. Provide restaurant seat count if applicable
- Landscape and Irrigation Plans
- Grease Interceptor sizing calculations
- Clearly defined legend including differentiation between existing and proposed utilities
- Match lines and key map for plan & profile sheets
- Number of meters per building and meter locations
- Gate valve locations for fire hydrants
- Lift station yard plan specific to the project including elevations at wet well and 4 corners, L – Dimension (see lift station detail) shown and actual proposed layout of gravity, FM, control panel etc.
- Engineer contact information including email address
- Owner (individual contact) information including email address
- Parcel ID number(s) provided on Cover Sheet
- Plans are signed and sealed



bringing you life's  
most precious resource