



NOTES:

1. A TEMPORARY JUMPER CONNECTION IS REQUIRED AT ALL CONNECTIONS BETWEEN EXISTING FDEP CLEARED POTABLE AND REUSE WATER MAINS AND PERMITTED WATER AND REUSE MAIN IMPROVEMENTS.
2. THE DETAIL ABOVE IS TO BE USED FOR PIGGING AND PRESSURE TESTING ALL PRESSURE MAINS AND FILLING, CHLORINATING, AND SAMPLING NEW POTABLE WATER MAINS.
3. UNTIL SUCH TIME AS FDEP HAS CLEARED THE POTABLE WATER MAIN FOR USE, OR TOHO HAS CLEARED THE POTABLE OR REUSE MAIN FOR USE IF NO FDEP PERMIT IS REQUIRED, THE JUMPER MUST REMAIN ON AND THE VALVE BETWEEN THE OLD AND NEW SYSTEMS MUST REMAIN CLOSED.
4. THE DEVELOPER AND/OR CONTRACTOR WILL PURCHASE THE TEMPORARY JUMPER ASSEMBLY FROM TOHO. ONLY JUMPERS PURCHASED AND INSTALLED BY TOHO ARE PERMITTED.
5. REMOVAL OR RELOCATION OF JUMPERS SHALL ONLY BE PERFORMED BY TOHO PERSONNEL.
6. 2" TAPS AND SERVICES UPSTREAM AND DOWNSTREAM OF THE JUMPER ASSEMBLY SHALL BE PER DETAIL TOHO-01.0, TOHO-01.1, AND TOHO-02.0.
7. GALVANIZED PIPE AND/OR FITTINGS ARE NOT ALLOWED.
8. ABANDONED JUMPER CONNECTIONS MUST BE INCLUDED ON THE FINAL RECORD DRAWINGS.



EFFECTIVE DATE:	04/01/2025
BOARD APPROVED DATE:	01/22/2025
PREVIOUS VERSION:	2022
DRAWN BY:	MP
REVISED BY:	DT

TEMPORARY JUMPER

DRAWING NUMBER

30